



GOVERNMENT OF ASSAM
OFFICE OF THE JOINT DIRECTOR OF HEALTH SERVICES
KAMRUP METROPOLITAN DISTRICT, SATPUKHURI, UZANBAZAR, GUWAHATI-1

No. Esstt/Jt.DHS(M)/Sanitation/2026-27/...4022...../

Dated.. 26/3/2026

CERTIFICATE OF HEALTH AND HYGIENE

NAME AND ADDRESS OF THE SCHOOL - **ST. FRANCIS DE SALES HIGHER
SECONDARY SCHOOL, SATGAON,
NARENGI, UDAYAN VIHAR,
GUWAHATI-781171.**

DATE OF INSPECTION - - - - - :- 25-03-2026.

POINT OF OBSERVATION :-

CLEANLINESS IN AND AROUND THE SCHOOL CAMPUS:-SATISFACTORY, MAINTAINED.

SAFE DRINKING WATER - - - - - :- AVAILABLE

URINAL & LATRINE'S CONDITION AND
NUMBER OF TOILETS - - - - - :- GOOD, SUFFICIENT IN NUMBER
ALL ARE CLEAN AND HYGIENE

DRAINAGE SYSTEM OF THE CAMPUS - - - - - :- GOOD

GENERAL CONDITION OF THE SCHOOL - - - - - :- GOOD

RATIO OF STUDENTS TO TEACHER - - - - - :- MAINTAINED

FIRE SAFETY MEASURES - - - - - :- MAINTAINED

AVAILABILITY OF THE FIRST AID BOX - - - - - :- AVAILABLE.

In view of the above, this is to Certify that the **ST. FRANCIS DE SALES HIGHER
SECONDARY SCHOOL, SATGAON, NARENGI, UDAYAN VIHAR, GUWAHATI-781171** is
maintaining good health and hygiene in and around the School.

The above Certificate is valid for the year 2026-2027.


Joint Director of Health Services
Kamrup Metropolitan District
Uzanbazar, Guwahati-1.
Joint Director of Health Services
Kamrup Metro, Guwahati-1

N.B :- When necessary Inspection may be visited at any time for hygiene and Sanitation
Maintenance.



TC-10845

**STATE PUBLIC HEALTH LABORATORY, ASSAM
BAMUNIMAIDAM, GUWAHATI-781021**

Email: foodanalyst@sphlassam.orgWebsite: www.sphlassam.org

Office Contact No. +91 7099015100

No. VII-170/2026/ 2119, Dated Guwahati, the 07/03/ /2026

REPORT ON ANALYSIS OF DRINKING WATER (IS 10500:2012)

Customer Name & Address : St. Francis De Sales. School
Add. Udayan Vihar, Narengi, Patharquary

Sample Description : Bore well water

Your No. : -

Place of Collection : St. Francis De Sales,
Add. Udayan Vihar, Narengi, Patharquary

Date of Receipt : 20.02.2026

Date of Analysis : Start: 05.03.2026; End: 05.03.2026

Physical Appearance : Clear

Sl. No	Parameter	Nature of method used	Result	Prescribed standard as per Food Safety and Standards Regulation-2.10.9 of Food Safety and Standards (Food Products Standards and Food Additives) Regulation, 2011 and IS 10500:2012
1	Turbidity, NTU	FSSAI 14.007:2024	0.0	5 (Max)
2	pH Value	FSSAI 14.004:2024	6.5	6.5 to 8.5
3	Total Hardness (as CaCO ₃), mg/l	FSSAI 14.026:2024	34.0	200 (Max)
4	Iron (as Fe), mg/l	FSSAI 14.047:2024	0.02	0.30 (Max)
5	Chloride (as Cl), mg/l	FSSAI 14.018:2024	2.77	250 (Max)
6	Residual Free Chlorine mg/l	FSSAI Manual of Methods for	Nil	0.20 (Max)





**STATE PUBLIC HEALTH LABORATORY, ASSAM
BAMUNIMAIDAM, GUWAHATI-781021**



TC-10845

Email: foodanalyst@sphlassam.orgWebsite: www.sphlassam.org

Office Contact No. +91 7099015100

Sl. No	Parameter	Nature of method used	Result	Prescribed standard as per Food Safety and Standards Regulation-2.10.9 of Food Safety and Standards (Food Products Standards and Food Additives) Regulation, 2011 and IS 10500:2012
		Analysis of Water Page 116		
7	Fluoride, (as F), mg/l	FSSAI 14.023:2024	0.8	1.0 (Max)
8	Total dissolved solids, mg/l	FSSAI 14.008:2024	56.0	500 (Max)
9	Total Calcium, (as Ca), mg/l	FSSAI 14.035:2024	4.8	75 (Max)
10	Magnesium, (as Mg), mg/l	FSSAI 14.022:2024	5.37	30 (Max)
11	Sulphate, (as SO ₄), mg/l	FSSAI 14.028:2024	Nil	200 (Max)
12	Total alkalinity (as CaCO ₃) mg/l	FSSAI 14.027:2024	35.7	200 (Max)

Note: Results are only with respect to the items tested. All tests are performed in the laboratory location only. Results apply to the sample as received.

Opinion: The sample of water conforms to the prescribed standards for drinking water as per IS 10500:2012 with respect to the analysis of the tested parameters.



Dated Guwahati, the 07.03.2026

(Kalyanee Bargohain)

Food Analyst, Dist. Kamrup (M) (Assam)

The report shall not be reproduced except in full, without the approval of the laboratory.

---End of Report---